



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1134 - CPR – 126

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the products Construction Products Regulation or CPR), this certificate applies to the construction product:

Optical Smoke Alarm Device Risco RWX34S

(Conventional detector)
(3 VDC Lithium battery)

with the performances listed in annex 1 of the EC certificate of constancy of performance and
intended use: Fire safety

manufactured by:

RISCO Ltd.
Hachoma Street 14
75655 RISHON LEZION
ISRAEL

and produced in the manufacturing plant(s):

Wizmart Technology Inc.
Tong-Hui Road 123
Jiang-Bei Pioneering Park
Ning Bo, 315033 Zhe-Jiang
CHINA

This certificate attests that all provisions concerning the assessment and the verification of constancy performance at system 1 being certified and the performances described in Annex ZA of the standard(s):


EN 14604:2005/AC:2008

are applied and that

the product fulfils to all here above mentioned and prescribed requirements.

This certificate was first issued on **2013-11-06** and remains valid as a long time as the testing methods and/or for the control of the production in factory included in the harmonized standard, used to evaluate the performances of the declared characteristics, do not change and as neither the product, nor the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Brussels, the 6th of November, 2013


Michèle VANDENDOREN
Secretary General



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

Annex 1 to CERTIFICATE CONSTANCY OF PERFORMANCE

1134 - CPR – 126

Harmonised technical specification		EN 14604: 2005 AC: 2008
Essential Characteristics	Performance 1) 2)	Clause
Nominal activation conditions / sensitivity / Response delay (response time) and performance under fire conditions - Smoke alarm signals - Inter-connectable smoke alarms - Repeatability - Directional dependence - Initial sensitivity - Air movement - Dazzling - Fire sensitivity - Sound output - Sounder durability - Inter-connectable smoke alarms - Alarm silence facility	pass NA pass pass pass pass pass pass pass pass NA NA	4.12 4.18 5.2 5.3 5.4 5.5 5.6 5.15 5.17 5.18 5.19 5.20
Operational reliability - Compliance - Individual alarm indicator - Mains-on indicator - Connection of external ancillary devices - Means of calibration - User replaceable components - Normal power source - Standby power source - Electrical safety requirements - Routine test facility - Terminals for external conductors - Battery removal indication - Battery connections - Battery capacity - Protection against the ingress of foreign bodies - Additional requirements for software controlled smoke alarms/ Marking and data - Impact - Battery fault warning - Battery reversal - Back-up power source	pass pass NA NA pass pass pass NA pass pass NA pass pass pass pass pass pass pass pass pass pass NA	4.1 4.2 4.3 4.4 4.5 4.6 4.7 4.8 4.9 4.10 4.11 4.13 4.14 4.15 4.16 4.17 4.19 5.11 5.16 5.22 5.23

Brussels, the 6th of November, 2013

Michèle VANDENDOREN

Secretary General



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

- <i>Electrical safety – assessment and testing to determine the adequacy of personal protection against hazardous currents passing through the human body (electric shock), excessive temperature and the start and spread of fire</i>	<i>pass</i>	5.24
<i>Tolerance to supply voltage</i> - <i>Variation in supply voltage</i>	<i>pass</i>	5.21
<i>Durability of operational reliability and response delay,</i> - <i>Dry heat</i> - <i>Cold (operational)</i>	<i>pass</i> <i>pass</i>	5.7 5.8
<i>Durability of operational reliability, vibration resistance</i> - <i>Vibration (operational)</i> - <i>Vibration (endurance)</i>	<i>pass</i> <i>pass</i>	5.12 5.13
<i>Durability of operational reliability, humidity resistance</i> - <i>Damp heat (operational)</i>	<i>pass</i>	5.9
<i>Durability of operational reliability, corrosion resistance</i> - <i>Sulphur dioxide (SO₂) corrosion</i>	<i>pass</i>	5.10
<i>Durability of operational reliability, electrical stability</i> - <i>Electromagnetic compatibility (EMC), immunity (operational)</i>	<i>pass</i>	5.14
¹⁾ "NPD" theoretically possible; except for durability of characteristics with declared performance ²⁾ "NA" not applicable for components to which the requirement does not apply		

Brussels, the 6th of November, 2013


Michèle VANDENDOREN
Secretary General



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

CERTIFICAT DE CONSTANCE DES PERFORMANCES

1134 - CPR – 126

Conformément au *Règlement 305/2011/EU du Parlement européen et du Conseil du 9 mars 2011* (le Règlement des Produits de la Construction ou CPR), ce certificat s'applique au produit de construction:

Détecteur optique de fumée – Détecteur Autonome

Risco RWX34S

(Détecteur conventionnel)
(3 VDC Lithium batterie)

dont les performances sont listées en annexe 1 au certificat de constance des performances
usage prévu : Sécurité incendie

fabriqué par:

RISCO Ltd.
Hachoma Street 14
75655 RISHON LEZION
ISRAEL

et fabriqué dans les établissements de fabrication:

Wizmart Technology Inc.
Tong-Hui Road 123
Jiang-Bei Pioneering Park
Ning Bo, 315033 Zhe-Jiang
CHINA

Ce certificat atteste que toutes les dispositions concernant l'évaluation et la vérification de la constance des performances et les performances décrites dans l'annexe ZA de la norme:

EN 14604:2005/AC:2008

sous le système 1 sont appliquées et que

le produit satisfait à toutes les exigences prescrites et mentionnées ci-dessus.

Ce certificat a été émis pour la première fois le **2013-11-06** et reste valable aussi longtemps que les méthodes d'essai et/ou pour le contrôle de la production en usine reprises dans la norme harmonisée, utilisées pour évaluer les performances des caractéristiques déclarées, ne changent pas et pour autant que ni le produit, ni les conditions de fabrication dans l'établissement de fabrication ne soient modifiés de manière significative.

Bruxelles, le 6 novembre 2013


Michèle VANDENDOREN
Secretary General



Notified body No. 1134
asbl **ANPI** vzw
Parc Scientifique Fleming - Granbonpré 1
B-1348 Louvain-la-Neuve

Annexe 1 au CERTIFICAT DE CONSTANCE DE PERFORMANCE
1134 - CPR – 126

Spécification technique harmonisée		EN 14604: 2005 AC: 2008
Caractéristiques essentielles	Performance 1) 2)	Clause
<i>Conditions nominales de déclenchement / sensibilité, délai de réponse (temps de réponse) et performance en condition de feu</i>		
- Signaux du détecteur	pass	4.12
- Détecteurs interconnectables	NA	4.18
- Répétabilité	pass	5.2
- Influence de la direction	pass	5.3
- Sensibilité initiale	pass	5.4
- Influence des courants d'air	pass	5.5
- Eblouissement	pass	5.6
- Sensibilité au feu	pass	5.15
- Puissance acoustique	pass	5.17
- Durabilité du dispositif sonore	pass	5.18
- Détecteurs interconnectables	NA	5.19
- Dispositif de neutralisation d'alarme	NA	5.20
<i>Fiabilité opérationnelle</i>		
- Conformité	pass	4.1
- Indicateur d'alarme individuel	pass	4.2
- Indicateur de présence de secteur	NA	4.3
- Connexion de dispositifs auxiliaires externes	NA	4.4
- Moyens de calibration	pass	4.5
- Composants remplaçables par l'utilisateur	pass	4.6
- Source d'alimentation principale	pass	4.7
- Source d'alimentation stand-by	NA	4.8
- Exigences sécurité électrique	pass	4.9
- Moyen de test de routine	pass	4.10
- Bornes pour conducteurs externes	NA	4.11
- Indication d'enlèvement de batterie	pass	4.13
- Connexion de la batterie	pass	4.14
- Capacité de la batterie	pass	4.15
- Protection contre l'accès de corps étrangers	pass	4.16
- Exigences supplémentaires pour les détecteurs utilisant un logiciel	pass	4.17
- Marquage et informations	pass	4.19
- Impact	pass	5.11
- Essai de signal de défaut de batterie	pass	5.16
- Inversion de la polarité	pass	5.22
- Source d'alimentation de secours	NA	5.23

Bruxelles, le 6 novembre 2013

Michèle VANDENDOREN
Secretary General



Notified body No. 1134
 asbl **ANPI** vzw
 Parc Scientifique Fleming - Granbonpré 1
 B-1348 Louvain-la-Neuve

- Sécurité électrique – évaluation et essais pour déterminer le caractère adéquate de la protection individuelle contre les courants dangereux traversant le corps humain (choc électrique), la température excessive et le démarrage et la propagation d'un incendie	pass	5.24
Tolérance de la tension d'alimentation - Variation de la tension d'alimentation	pass	5.21
Durabilité de la fiabilité opérationnelle, du délai de réponse, résistance à la température - Chaleur sèche - Froid (opérationnel)	pass pass	5.7 5.8
Durabilité de la fiabilité opérationnelle, résistance aux vibrations - Vibrations (opérationnel) - Vibrations (endurance)	pass pass	5.12 5.13
Durabilité de la fiabilité opérationnelle, résistance à l'humidité - Chaleur humide (opérationnel)	pass	5.9
Durabilité de la fiabilité opérationnelle, résistance à la corrosion - Corrosion par SO ₂	pass	5.10
Durabilité de la fiabilité opérationnelle, stabilité électrique - Compatibilité électromagnétique (CEM), essais d'immunité (essais fonctionnels)	pass	5.14
¹⁾ "NPD" ou "PND" théoriquement possible ; excepté pour la durabilité des caractéristiques avec des performances déclarées ²⁾ "NA" "non applicable" pour les composants auxquels la condition ne s'applique pas		

Bruxelles, le 6 novembre 2013


Michèle VANDENDOREN
Secretary General